

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-1373:113 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** First Alert Professional, 165 Eileen Way, Syosset NY 11891  
Contact: David Kalmus (516) 921-6704

**DESIGN:** Model FA1600C fire alarm control unit. Power-limited. Automatic, manual, noncoded, local, remote station, central station, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. Minimum system components:

FA1600C	Control Unit
1451	Transformer
FA250KP, FA550KP	Keypad

**RATING:** Primary 120 VAC, 18 VAC Secondary, 12 VDC Standby

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

\*This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:**

1. For **Fire Alarm Verification Feature** (delay of fire alarm), the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.
2. Burglary and other non-fire functions were not examined.

**XLF:** 7165-0078:174

\*Corrected 07-20-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager